

## § 72.106

(1) Planned discharges of radioactive materials, radon and its decay products excepted, to the general environment,

(2) Direct radiation from ISFSI or MRS operations, and

(3) Any other radiation from uranium fuel cycle operations within the region.

(b) Operational restrictions must be established to meet as low as is reasonably achievable objectives for radioactive materials in effluents and direct radiation levels associated with ISFSI or MRS operations.

(c) Operational limits must be established for radioactive materials in effluents and direct radiation levels associated with ISFSI or MRS operations to meet the limits given in paragraph (a) of this section.

[53 FR 31658, Aug. 19, 1988, as amended at 63 FR 54562, Oct. 13, 1998]

### § 72.106 Controlled area of an ISFSI or MRS.

(a) For each ISFSI or MRS site, a controlled area must be established.

(b) Any individual located on or beyond the nearest boundary of the controlled area may not receive from any design basis accident the more limiting of a total effective dose equivalent of 0.05 Sv (5 rem), or the sum of the deep-dose equivalent and the committed dose equivalent to any individual organ or tissue (other than the lens of the eye) of 0.5 Sv (50 rem). The lens dose equivalent shall not exceed 0.15 Sv (15 rem) and the shallow dose equivalent to skin or to any extremity shall not exceed 0.5 Sv (50 rem). The minimum distance from the spent fuel or high-level radioactive waste handling and storage facilities to the nearest boundary of the controlled area must be at least 100 meters.

(c) The controlled area may be traversed by a highway, railroad or waterway, so long as appropriate and effective arrangements are made to control traffic and to protect public health and safety.

[53 FR 31658, Aug. 19, 1988, as amended at 63 FR 54562, Oct. 13, 1998]

### § 72.108 Spent fuel or high-level radioactive waste transportation.

The proposed ISFSI or MRS must be evaluated with respect to the potential impact on the environment of the

## 10 CFR Ch. I (1–1–00 Edition)

transportation of spent fuel or high-level radioactive waste within the region.

### Subpart F—General Design Criteria

#### § 72.120 General considerations.

(a) Pursuant to the provisions of § 72.24, an application to store spent fuel in an ISFSI or to store spent fuel or high-level radioactive waste in an MRS must include the design criteria for the proposed storage installation. These design criteria establish the design, fabrication, construction, testing, maintenance and performance requirements for structures, systems, and components important to safety as defined in § 72.3. The general design criteria identified in this subpart establish minimum requirements for the design criteria for an ISFSI or MRS. Any omissions in these general design criteria do not relieve the applicant from the requirement of providing the necessary safety features in the design of the ISFSI or MRS.

(b) The MRS must be designed to store either spent fuel or solid high-level radioactive wastes. Liquid high-level radioactive wastes may not be received or stored in an MRS. If the MRS is a water-pool type facility, the solidified waste form shall be a durable solid with demonstrable leach resistance.

#### § 72.122 Overall requirements.

(a) *Quality Standards.* Structures, systems, and components important to safety must be designed, fabricated, erected, and tested to quality standards commensurate with the importance to safety of the function to be performed.

(b) *Protection against environmental conditions and natural phenomena.* (1) Structures, systems, and components important to safety must be designed to accommodate the effects of, and to be compatible with, site characteristics and environmental conditions associated with normal operation, maintenance, and testing of the ISFSI or MRS and to withstand postulated accidents.